

Siemens AG, A&D SE S 6, P.O. Box 23 55, 90713 Fuerth

Name	Yves Krüll
Department	A&D SE S 6
Telephone	+49 (911) 750-2625
Fax	+49 (911) 750-2246
Mobile	+49 (151) 16703557
E-mail	yves.kruell@siemens.com
Your letter of	
Our reference	ky2625
Date	March 31, 2008

### Information about declaration of CE-conformity SINVERT solar inverters (60 Hz)

To whom it may concern,

The declaration of conformity for the SINVERT solar inverters is issued separately for each inverter after its production.

In this letter we give information about the producer of SINVERT solar inverters and about the compliance of standards. The information given in this letter is valid until a standardized declaration of CE conformity is available for each respective inverter type.

Manufacturer: Siemens AG  
Automation & Drives  
Systems Engineering, S6

Address: Wuerzburger Strasse 121  
90766 Fuerth  
Germany

Product name: SINVERT solar (60 Hz)

Inverter types:	SINVERT solar 100 M – 1DC	SINVERT solar 400 MS – 12DC
	SINVERT solar 100 M – 3DC	SINVERT solar 420 M
	SINVERT solar 200 M – 2DC	SINVERT solar 700 MS
	SINVERT solar 200 M – 6DC	SINVERT solar 850 MS
	SINVERT solar 300 M – 3DC	SINVERT solar 1000 MS
	SINVERT solar 300 M – 9DC	SINVERT solar 1300 MS
	SINVERT solar 350 M	SINVERT solar 1400 MS
	SINVERT solar 400 MS – 4DC	SINVERT solar 1700 MS

Siemens AG  
Industry Sector  
Head: Heinrich Hiesinger

Postal address:  
Siemens AG  
A&D SE S 6  
P.O. Box 23 55  
90713 Fuerth


Office address:  
Wuerzburger Str. 121  
90766 Fuerth  
Tel: +49 (911) 750 0  
Fax: +49 (911) 750 2992

Siemens Aktiengesellschaft: Chairman of the Supervisory Board: Gerhard Cromme  
Managing Board: Peter Loescher, Chairman, President and Chief Executive Officer; Wolfgang Dehen, Heinrich Hiesinger, Joe Kaeser, Erich R. Reinhardt, Hermann Requardt, Siegfried Russwurm, Peter Y. Solmssen  
Registered offices: Berlin and Munich; Commercial registries: Berlin Charlottenburg, HRB 12300, Munich, HRB 6684  
WEEE-Reg.-No. DE 23691322

Standards: EN 61000-6-2  
EN 61000-6-4 (radiated emissions)\*  
EN 60439-1

\* required emission level is met for the whole system including medium voltage transformer

Sincerely yours,

- 

Stefan David  
Director A&D SE S6